

THE GAUHATI HIGH COURT  
(THE HIGH COURT OF ASSAM:NAGALAND:MIZORAM AND ARUNACHAL PRADESH)

KOHIMA BENCH

NOTICE INVITING QUOTATION

Dated Kohima, the 24<sup>th</sup> May' 2026.

NO.HC(K)19/2022/Estt/ 1534 ::::: Sealed quotations affixing Court Fee Stamp of ₹8.25 (non-refundable) are hereby invited from suppliers/dealers/firms dealing in IT related items and having permanent shops within the Kohima Municipal Area, Kohima, for the supply and installation of the following item to the office of the undersigned:

1. **1 (One) no. of 10 kVA Online UPS (3:3 or 3:1 Phase) along with batteries.**

The specifications/configurations of the above items are enclosed at Annexure–A for reference.

TERMS AND CONDITIONS

1. The quotation closing date is 11:00 hrs of 08.06.2026 and will be opened on the same day at 13:00 hrs in presence of all the tenderers.
2. The tenderers are to quote only one rate for each item. The rate should be exclusive of G.S.T. The sealed quotation should be superscribed as “**Quotation for 1 (One) no. of 10 kVA Online UPS (3:3 or 3:1 Phase) along with batteries**” and addressed to: The Registrar, Gauhati High Court Kohima Bench, Kohima – 797 001, Nagaland.
3. The suppliers/dealers/firms must be based in Kohima and possess a valid GSTIN. copy of GST registration certificate, trade license and PAN card must be submitted along with the quotation.
4. The supply and installation should be made within 1(one) week from the date of issue of supply order.
5. Quotation once submitted will not be allowed to be withdrawn till finalization of the whole matter. The office reserve the right to reject the whole quotation or item/ items or whole tender process without assigning any reason thereof. No conditional quotation will be accepted. The decision of the Registrar in all respect shall be final and binding.
6. In case of violation of terms and conditions or unsatisfactory supply of items or of poor quality and below standard, the Registrar, Gauhati High Court Kohima Bench, Kohima reserves the right to terminate the supply order with/without giving prior intimation to the supplier.

(AJONGBA IMCHEN, NJS)

Registrar

Gauhati High Court Kohima Bench

Dated Kohima, the 21<sup>st</sup> May' 2026.

Memo. No.HC(K)19/2022/Estt/ 1534

Copy to:

1. The Programmer/Systems Officer, Gauhati High Court Kohima Bench for uploading in Kohima Bench website.
2. Notice Board

(AJONGBA IMCHEN, NJS)

Registrar

Gauhati High Court Kohima Bench

ANNEXURE-A

**Data Sheet: 10 kVA Online UPS (3:3 or 3:1 Phase)**

<b>Category</b>	<b>Parameter</b>	<b>Required Specification</b>	<b>Vendor Response (Compliance)</b>
<b>SYSTEM</b>	<b>Rating</b>	10 kVA / 10 kW (Unity PF preferred)	
	<b>Topology</b>	True Online Double Conversion (VFI-SS-111)	
<b>INPUT</b>	<b>Phase Configuration</b>	3-Phase + Neutral + Ground (PE)	
	<b>Voltage Range</b>	304V – 477V AC at full load	
	<b>Frequency Range</b>	45 Hz – 65 Hz	
	<b>Input Power Factor</b>	≥ 0.99 at full load	
	<b>Current THDi</b>	< 3% for linear / < 5% for non-linear load	
<b>OUTPUT</b>	<b>Voltage (Nominal)</b>	380V/400V/415V (3-phase) or 220V/230V/240V (1-phase)	
	<b>Voltage Regulation</b>	± 1% (Static)	
	<b>Waveform</b>	Pure Sine Wave	
	<b>Overload Capacity</b>	125% for 10 min; 150% for 1 min	
	<b>Efficiency</b>	≥ 95% (Online Mode) / ≥ 99% (ECO Mode)	

<b>Battery</b>	<b>Battery Type</b>	Sealed Maintenance Free (SMF) VRLA	
	<b>Nominal DC Voltage</b>	192 VDC or 240 VDC (typical)	
	<b>Backup Time</b>	[User to specify, e.g., 120 mins]	
<b>Mechanical</b>	<b>Ingress Protection</b>	IP20	
	<b>Noise Level</b>	< 60 dBA at 1 meter	
<b>Comms</b>	<b>Interfaces</b>	SNMP Card, RS232, RS485, USB, Dry Contacts	
	<b>Indicators</b>	LCD display for V, I, f, Load %, and Alarms	
<b>Service</b>	<b>Warranty</b>	[Specify, e.g., 3 Years for UPS / 1 Years for Battery]	

**Mandatory Compliance Checklist.**

- **Built-in Bypass:** Must include Static and Maintenance Manual Bypass.
- **Cold Start:** UPS must be capable of starting directly from batteries without utility power.
- **Protection:** Inbuilt protection for short circuits, over-temperature, and surge.
- **Certifications:** Compliance with IEC 62040-1 (Safety), IEC 62040-2 (EMC), and ISO 9001/14001.