

THE GAUHATI HIGH COURT
(THE HIGH COURT OF ASSAM: NAGALAND: MIZORAM AND ARUNACHAL PRADESH)
KOHIMA BENCH

NOTICE INVITING QUOTATION

Dated Kohima, the 13th July 2026

NO.HC(K)19/2022/Estt/ 2135 : Sealed quotations affixing Court Fee Stamp of ₹8.25 (non-refundable) are hereby invited from suppliers/dealers/firms dealing in IT related items and having permanent shops within the Kohima Municipal Area, Kohima, for the supply and installation of the following item to the office of the undersigned:

1. 1 (One) no. of 10 kVA Online UPS (3:3 Phase).

The specifications/configurations of the above items are enclosed at Annexure A for reference.

TERMS AND CONDITIONS

1. The quotation closing date is 11:00 hrs of 28.07.2026 and will be opened on the same day at 13:00 hrs in presence of all the tenderers.
2. The tenderers are to quote only one rate for each item. The rate should be exclusive of G.S.T. The sealed quotation should be superscribed as **"Quotation for 1 (One) no. of 10 kVA Online UPS (3:3 Phase)"** and addressed to: The Registrar, Gauhati High Court Kohima Bench, Kohima – 797001, Nagaland.
3. The suppliers/dealers/firms must be based in Kohima and possess a valid GSTIN. A copy of GST registration certificate, Trade license and PAN card must be submitted along with the quotation.
4. The successful bidders have to submit security deposit of ₹20,000/- (Rupees Twenty Thousand) only, (refundable) in the form of Demand draft/Bank guarantee in favour of Registrar, Gauhati High Court Kohima Bench payable at Kohima.
5. The supply and installation should be made within 1(one) week from the date of issue of supply order.
6. Quotation once submitted will not be allowed to be withdrawn till finalization of the whole matter. The office reserve the right to reject the whole quotation or item/ items or whole tender process without assigning any reason thereof. No conditional quotation will be accepted. The decision of the Registrar in all respect shall be final and binding.
7. In case of violation of terms and conditions or unsatisfactory supply of items or of poor quality and below standard, the Registrar, Gauhati High Court Kohima Bench, Kohima reserves the right to terminate the supply order with/without giving prior intimation to the supplier.

(AJONGBAIMCHEN, NJS)

Registrar

Gauhati High Court Kohima Bench

Dated Kohima, the 13th July 2026

Memo. No.HC(K)19/2022/Estt/ 2135

Copy to:-

- ✓ The Programmer/Systems Officer, Gauhati High Court Kohima Bench for uploading in Kohima Bench website.
2. Notice Board

(AJONGBAIMCHEN, NJS)

Registrar

Gauhati High Court Kohima Bench

ANNEXURE-A

Data Sheet: 10 kVA Online UPS (3:3 Phase)

Category	Parameter	Required Specification	Vendor Response (Compliance)
SYSTEM	Rating	10 kVA / 10 kW (Unity PF preferred)	
	Topology	True Online Double Conversion (VFI-SS-111)	
INPUT	Phase Configuration	3-Phase + Neutral + Ground (PE)	
	Voltage Range	304V – 477V AC at full load	
	Frequency Range	45 Hz – 65 Hz	
	Input Power Factor	≥ 0.99 at full load	
	Current THDi	$< 3\%$ for linear / $< 5\%$ for non-linear load	
OUTPUT	Voltage (Nominal)	360V DC to 384V DC (3-phase)	
	Voltage Regulation	$\pm 1\%$ (Static)	
	Waveform	Pure Sine Wave	
	Overload Capacity	125% for 10 min; 150% for 1 min	
	Efficiency	$\geq 95\%$ (Online Mode) / $\geq 99\%$ (ECO Mode)	

Mandatory Compliance Checklist.

- **Built-in Bypass:** Must include Static and Maintenance Manual Bypass.
- **Protection:** Inbuilt protection for short circuits, over-temperature, and surge.